**NOTICE TO RESPONDENTS**

Responses to an Invitation to Bid will be received by the Purchasing Supervisor in the SUPPORT

| | SCHOOL | TYPE OF SYSTEM |
|---|---|---|
| 1 | BEECH ELEMENTARY<br>3120 LONG HOLLOW PIKE<br>HENDERSONVILLE, TN 37075 | COOLING TOWER<br>COMMON CLOSED LOOP |
| 2 | BEECH HIGH<br>3126 LONG HOLLOW PIKE<br>HENDERSONVILLE, TN 37075 | COOLING TOWER<br>COMMON CLOSED LOOP |
| 3 | BETHPAGE ELEMENTARY<br>420 OLD HWY 31<br>BETHPAGE, TN 37022 | COOLING TOWER<br>COMMON CLOSED LOOP |
| 4 | BENNY BILLS ELEMENTARY<br>1030 UNION SCHOOL ROAD<br>GALLATIN, TN 37066 | GEO-THERMAL |
| 5 | SUMNER COUNTY BOARD OF EDUCATION<br>CENTRAL OFFICE<br>695 EAST MAIN STREET<br>GALLATIN, TN 37066 | GEO-THERMAL |
| 6 | E.B. WILSON NIGHT SCHOOL<br>102 INDIAN LAKE ROAD<br>HENDERSONVILLE, TN | HOT LOOP |
| 7 | ELLIS MIDDLE<br>100 INDIAN LAKE ROAD<br>HENDERSONVILLE, TN 37075 | CLOSED LOOP<br>HOT LOOP |
| 8 | GALLATIN HIGH<br>700 DAN P. HERRON DRIVE<br>GALLATIN, TN 37066 | GEO-THERMAL |
| 9 | GEORGE WHITTEN ELEMENTARY<br>140 SCOTCH STREET<br>HENDERSONVILLE, TN 37075 | COOLING TOWER<br>CHILLED LOOP<br>HOT LOOP |
| 10 | GUILD ELEMENTARY | COOLING TOWER |

| | | |
|---|---|---|
| 13 | HENDERSONVILLE HIGH<br>123 CHEROKEE ROAD<br>HENDERSONVILLE, TN 37075 | CHILLED 1 CHILLED 2<br>HOT LOOP<br>ICE BUILD SYSTEM |
| 14 | INDIAN LAKE ELEMENTARY<br>505 INDIAN LAKE ROAD<br>HENDERSONVILLE, TN 37075 | COOLING TOWER<br>COMMON CLOSED LOOP |
| 15 | JACK ANDERSON ELEMENTARY<br>250 SHUTES LANE<br>HENDERSONVILLE, TN 37075 | COOLING TOWER<br>COMMON CLOSED LOOP |

| | | |
|---|---|---|
| 39 | WHITE HOUSE HIGH<br>508 TYREE SPRINGS ROAD<br>WHITE HOUSE, TN 37188 | CHILLED LOOP<br>HOT LOOP<br>ICE BUILD SYSTEM |
| 40 | WHITE HOUSE HIGH (ANNEX)<br>111 MEADOWS ROAD<br>WHITE HOUSE, TN 37188 | COOLING TOWER<br>COMMON CLOSED LOOP |
| 41 | WHITE HOUSE MIDDLE<br>2020 HWY 31W<br>WHITE HOUSE, TN 37188 | GEO-THERMAL |

feeder boards, pumps, and installation shall be included in the contract price. The feed equipment shall remain the property of the water treatment contractor and any maintenance required during the contract period shall also be included.

The automated solid biocide program shall use an oxidizing microbiocide to provide biological control.

The water treatment supplier must have the capability of testing for biological contamination and control. The supplier must also have the capability of running *Legionella* tests as required.

Cycles of concentration are to be maintained within a range of 4.0 to 5.0 wherever possible.

All existing conductivity controllers and chemical feed pumps to be used unless deemed unrepairable.

The use of the required solid feeder boards for the cooling towers and installation shall be included in the contract price. The feeder boards shall remain the property of the water treatment contractor and any maintenance required during the contract period shall also be included.

Provide a treatment program that uses nitrite/borate as the primary corrosion inhibitor with tolyltriazole for copper protection.

- Primary business activity is water treatment and must have been in business for a minimum of five years with water treatment as primary business activity and live within 50 miles.
- Must have laboratory facility capable of running typical water and deposit analysis, corrosion coupon studies, and bacteria analysis.
- Must have at least one full time staff member who has a college degree in chemistry or a related technical degree whose primary function is technical support.
- Primary service representative must have at least 1 year experience in field service.
- Must have at least one back-up service representative who meets the same criteria as the primary representative.
- S0.002 Tc 0.002 Tw 5.74 0 Td.kNBDo.002 in c.at cf(rat)-4(o)s primary1(r an)-4(d)b4( h)-3-4(ik)4(sd[u)-4(p

**Sumner County Board of Education**

Purchasing Department
1500 Airport Road
Gallatin, TN 37066

COMPANY NAME _____

ADDRESS _____

_____

TELEPHONE _____

EMAIL _____

AUTHORIZED COMPANY REPRESENTATIVE _____*SIGNATURE*

AUTHORIZED COMPANY REPRESENTATIVE _____*PRINTED*

DATE _____

BID TITLE

DEADLINE Tuesday, May 20, 2014 @ 9:00 a.m.

BID AMOUNT $_____ Monthly Payment

$_____ Yearly

Cost of five (5) gallons of solution to recharge drained loop (5 gal. of solution per 500 gal. of water) $_____

BID GOOD THRU _____

Name & Address of Laboratory: _____

_____

_____